

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220586
Address: 908 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Friday, April 28, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Complete all corrections for all other departments-Provide address at front and back of building-Complete installation of ATM and Lighting-Compelte parking lot signage-Cut exterior cleanout to grade-Provide box extensions at receptacles in restroom tile walls-Seal gap around receptacle and secure under sink in women's restroom-Provide min. air gap at condensate line and blow backflow blow off at mop sink-Provide GFCI protection under sink in breakroom-Secure rooftop seal tight from disconnect to RTUs-Clean all trash from roof
---	------	--

Comments: