

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226039

Address: 2117 SW OSAGE DR, LEES SUMMIT, MO 64082 2115 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Monday, May 01, 2023

Corrective Action Required:

1	Miscellaneous Correction	2115 and 2117
		2115
		-exterior is not ready for inspection
		TCO passed for 2115 only
		2117
		-garage door self closing hinge is not working
		-basement handrail not installed
		-basement door not installed
		-basement water anti siphon is not tightened and bolt removed
		-basement carbon monoxide detector not installed
		-exterior is not ready for inspection
		2117 failed inspection

Comments: