

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20220586  
Address: 908 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Monday, May 01, 2023

Corrective Action Required:

1	Misc	-Complete all corrections for all other departments -Provide address at front and back of building -Complete installation of ATM and Lighting -Compelte parking lot signage -Cut exterior cleanout to grade -Secure rooftop seal tight from disconnect to RTUs -Clean all trash from roof
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**