

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220586
Address: 908 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, May 01, 2023

Corrective Action Required:

1	Misc	-Complete all corrections for all other departments -Provide address at building side facing Pryor -Complete installation of ATM and Lighting -Compelte parking lot signage -Cut exterior cleanout to grade -Secure rooftop seal tight from disconnect to RTUs -Clean all trash from roof **OK for furniture
---	------	---

Comments: