

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220226  
Address: 4871 SW RAINTREE PKWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Monday, May 01, 2023

Corrective Action Required:

1	Miscellaneous Correction	-basement cook top needs a vent installed -basement bathroom fixtures not completed -kitchen hood vent is not installed -garage to house door needs a self closing hinge installed -sod and splash guards not installed -driveway and sidewalks not installed
---	-----------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**