

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223170
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|-----------------------|
| Water Line - Construction Inspection | John Jackson | Partial | Tuesday, May 02, 2023 |

Informational:

| | | |
|---|------|--|
| 1 | Misc | 05/01/23 Monday (Burnaugh Const.) Contractor expose existing 12" pipe for tap for domestic meter. 05/02/23 Tuesday (Burnaugh Construction) Contractor began installation of domestic water meter and 2" "K" water line transitioning to blue poly, after the City of Lee's Summit installed 12"X2" tap & sleeve at 12" existing main. |
|---|------|--|

Comments: