

Steven Robbins

From: Joe San Nicolas
Sent: Tuesday, May 2, 2023 2:11 PM
To: Steven Robbins
Cc: Mark Harding; Robb Popp
Subject: RE: 2091 NW. O'Brien

Steve,

Raising 3" will be ok on this one. We will still be able to perform maintenance on this one at estimated final grade.

From: Steven Robbins <Steve.Robbins@cityofls.net>
Sent: Tuesday, May 2, 2023 1:25 PM
To: Joe San Nicolas <Joe.SanNicolas@cityofls.net>
Cc: Mark Harding <Mark.Harding@cityofls.net>; Robb Popp <Robb.Popp@cityofls.net>
Subject: RE: 2091 NW. O'Brien

Thank You!

From: Joe San Nicolas <Joe.SanNicolas@cityofls.net>
Sent: Tuesday, May 2, 2023 1:24 PM
To: Steven Robbins <Steve.Robbins@cityofls.net>
Cc: Mark Harding <Mark.Harding@cityofls.net>; Robb Popp <Robb.Popp@cityofls.net>
Subject: RE: 2091 NW. O'Brien

Steve,

I'll be by that way shortly and provide feedback soon. Thanks for reaching out.

Yours Truly,

Joe San Nicolas | Metered Services Supervisor
1200 SE Hamblen Road | Lee's Summit, MO 64081
816.969.1910 | lswater.net | Joe.SanNicolas@cityofls.net



From: Steven Robbins <Steve.Robbins@cityofls.net>
Sent: Tuesday, May 2, 2023 12:06 PM
To: Joe San Nicolas <Joe.SanNicolas@cityofls.net>
Cc: Mark Harding <Mark.Harding@cityofls.net>; Robb Popp <Robb.Popp@cityofls.net>
Subject: 2091 NW. O'Brien

Hi Joe,

I had a contractor call in about a water meter that is about 1" too low (per the contractor) he needs to raise the pit up about 3" to get it to grade. Can you take a look at this to see if it is acceptable from water. The permit # is 20222963.

Thanks,
Steve

Yours Truly,

Steve Robbins | Asst. Dir. of Field Services
220 SE Green Street | Lee's Summit, MO 64063
816.969.1228 | cityofLS.net | Steve.Robbins@cityofls.net

