

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20215796  
Address: 2026 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, May 04, 2023

Informational:	
1      Misc	PORTAL FRAME INSPECTION ONLY. -UNCOVER NAILING TO HEADER -SHEATHING BREAKS TO OCCUR IN THE MIDDLE 24" OF PORTAL LEG
Corrective Action Required:	
2      Misc	-fireblock right of garage entry into furr down -fireblock furr down ends in basement see beam ends Okay to insulate

**Comments:**