

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222242
Address: 530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	Khanh Nguyen	Failed	Thursday, May 04, 2023

Informational:
1 Misc

- All light pole piers ok
- Underground raceway shall be min 18" below grade and min 24" below driveway/parking pavement
- Light poles not grounded. Verify all grounding to rods

Comments: