

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222245
Address: 1430 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, May 04, 2023

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Secure drainage piping and cut off 1" above flood level rim at mop sink -Provide panel schedules and label panels -Provide ASSE 1022 or 1024 backflow devices at all beverage machines -Provide permanent address at Douglas side of building
---	------	--

*OK to stock and train-not approved for public

Comments: