

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222245
Address: 1430 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Punch List Inspection	John Jackson	Partial	Thursday, May 04, 2023

Informational:

1 Misc

1. ADA sidewalks on both sides of North entrance need to be repaired.
2. Water valve box needs to be cut to grade.
3. Sodding at the top of the hill on Eastside of building along the public sidewalk. Bushes and mulch will be installed Northside wrapping around East of building going to the South of building.

Comments: