

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213188
Address: 1908 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, May 05, 2023

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Obtain lawn irrigation permit and submit backflow valve test report to city. Permit application is incomplete **Irrigation permit is still in "incomplete" status |
| | | -Provide sewer tracer wire port at grade **not done |
| | | -Screw the exterior door embedded jamb brace into studs through the 4 pre-drilled holes with min 3" screws |

Comments: