

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212005  
Address: 516 SE CARTER RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Friday, May 05, 2023

Corrective Action Required:

1	Misc	-Front porch electrical outlet is not GFCI protected -wood penetrations above interior garage doors need to be sealed -not all splash pads are not installed -sidewalk inspection pending at the time of this inspection (9:35am) 05/02/2023 -sidewalk inspection is still pending (05/05/2023)
---	------	--

**Comments:**