

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216395
Address: 1613 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, May 08, 2023

Corrective Action Required:

1	Misc	-obtain issued lawn irrigation permit -sod -splash blocks and sump pump discharge to extend 36" from foundation -security screws at rear patio door -identify non labeled breaker in panel -tamper caps at A/c unit - water meter to grade ensure 14"-18" from meter to lid ring
---	------	--

Comments: