

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20223170  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:              | Inspector:   | Outcome: | Date:                |
|--------------------------|--------------|----------|----------------------|
| <b>Curb - Proof Roll</b> | John Jackson | Passed   | Monday, May 08, 2023 |

Informational:  
1 Misc

05/08/23 Monday JMJ ( Bradley Construction-Mike / Bill Bushy Concrete Construction )  
Curbs that were proof rolled passed. The curbs on the far South in of project was not proof roll because Bradley Construction Engineer were concern about the existing 6' metal storm pipe.  
Site Foreman Mike from Bradley Construction stated that the Engineer/Developer will write a letter stating they acknowledge a proof roll was not done at their requested. The integrity of the subgrade was not verified as-per contractors request.

**Comments:**