

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213190
Address: 1924 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, May 08, 2023

Corrective Action Required:

1	Misc	-address pending pier inspection -splash block and sump pump discharge to extend 36" from foundation -provide as graded plot plan -label all non GFCI outlets in unfinished spaces -security screws at rear patio door -identify sewer tracer wire -water meter well to grade. Ensure 14"-18" from meter top to lid ring -obtain lawn irrigation permit
---	------	--

Comments: