

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215858  
Address: 1700 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, May 09, 2023

Corrective Action Required:

1	Misc	-provide as graded plot plan -properly install spark ring above fireplace -provide provide gravel filter under water meter provide 6" of clearance underneath meter setter. Ensure 14"-18" from meter top to well lid ring.
---	------	---

**Comments:**