

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223368
Address: 2911 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, May 09, 2023

Informational:

1	Misc	Exterior wall grade beam approved to pour below: -West GB starting from C.5 to B/5 to B/3.5 to A/3.5 to A/2.3 to B/2.3 to B/1 to E.7; continue to H/5 SW corner; 5/H to 5/G, line ZD 5/G to Z7.5, Line I/1 to I/2; B/5 to B/2.3; line Z7/ZD to Z7/ZA to Z10/ZA to Z10/C.5 Column pads approved to pour below: -Col pads on lines 2,3,4,5; 4.6/G; 2 pads on line Z4.5; 2 col pads on line Z10, 3 pads on line ZE
---	------	--

Corrective Action Required:

2	Misc	Retaining wall at per L300-Provide min 36" frost depth per plan
---	------	---

Comments: