

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221450
Address: 185 SW WINTER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, May 09, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Provide missing window main floor stairs- Fb penetration top plate basement North west room- Provide door in basement walk out- Security blocking at door in sports room- - Provide B-vent for hearth fireplace- Nail exterior siding to code (at sill plate)- Provide missing deck posts
---	------	---

Comments: