

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224595
Address: 2122 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, May 09, 2023

Corrective Action Required:

1 Misc

- pfh at single car garage complete anchor bolts per design
- address over notched exterior wall stud W bed 2 wall
- fire block flex room E wall space to ceiling space
- fire block entry to ceiling space (see left of powder room entry
- fire blocking materials must comply with code section R302.11.1 of the 2018 IRC.
- fire block W bed 4 wall into furr down
- seal penetrations in RA panning above bed 4
- fire block all the wall space to ceiling space along W wall use approved materials
- provide proper support for csst T Above basement rec room /beds hall

Comments: