CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20201867Address:504 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Driveway Inspection		Steve Robbins	Passed	Tuesday, May 09, 2023
Informational:				
1	Misc	 1-28-21 9:50AM The driveway approach was not built to the Design and Construction Manual. This is a fail and will need to be replaced. It appears that there will be a drain issue without a drain pipe as well. 2-1-21 10:32am The forms are set and the aggregate is compacted. They have two drain pipes running through. They need to stay ADA compliant through 		
the driveway for the sidewalk. Informational:				
2	Misc	The driveway has been po	oured and has passed.	

Comments: