

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214832
Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Adam Nacke	Partial	Tuesday, May 09, 2023

Corrective Action Required:

1	Misc	5-9-23 NS Site visited this morning and the crew dug up the sewer line and cut it and put a new Y in. They are going to dig the new sewer line to the clean out. I will have pictures of the sewer connection.
---	------	--

Comments: