

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221053
Address: 3209 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, May 10, 2023

Corrective Action Required:

1 Misc

- provide nail guards garage N wall where needed for electrical one missing
- fireblock E garage wall into furr down (when using Unfaced insulation it must be packed tightly and securely)
- fire block furr down ends in garage (when using Unfaced insulation, it must be packed tightly and securely)
- uncover covered patio for inspection
- address roof Perlin supports not plans multiple areas
- missing hanger at attic access 2nd floor
- fire block furr down ends. In basement
- first block beam ends in basement
- provide strike plates at electrical where required in basement one missing
- service panel must maintain 36" minimum clearance in front of panel.

Comments: