

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231176

Address: 2127 SW OSAGE DR, LEES SUMMIT, MO 640822129 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Wednesday, May 10, 2023

Corrective Action Required:

1	Miscellaneous Correction	Silt fence along the front street needs to be reinstalled. The old fence is not serving its intended purpose. This is for 2127 and 2129 SW Osage
---	--------------------------	--

Comments: