

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225144
Address: 3202 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, May 10, 2023

Corrective Action Required:

1	Misc	(Waiting on engineers letter on correction made) - Address rafters landing on 4 blocks at entry and stairs - Address rafters landing on 4 blocks in master closet
---	------	---

OK to insulate

Comments: