

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231510
Address: 362 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Shawn Hoffman	Partial	Thursday, May 11, 2023

Corrective Action Required:

1	Misc	-Bonded at 6 points on the pool and 2 points on the hot tub
		- Grounding wire to top of pool walls. Shawn Hoffman 05/11/2023 10:52 AM
		-Ok to pour floor

Comments: