

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204940
Address: 322 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, May 11, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Obtain an irrigation permit and submit a back flow certification- Repair studs supporting stairs landing at DWV in basement by sump- Attach whip for A/ C 12" from disconnect- Repair slope of grade away from foundation at garage wall and at A/C compressor
---	------	---

Comments: