



Architect's Supplemental Instructions (ASI's)

307B SW Market Street
Lee's Summit, MO 64063
816.249.2270
info@collinsandwebb.com

Project: iTAP
Issue Date: April 13, 2023
ASI No.: TI- 01

THIS DOCUMENT HAS IMPORTANT LEGAL CONSEQUENCES; CONSULTATION WITH AN ATTORNEY IS ENCOURAGED WITH RESPECT TO ITS COMPLETION OR MODIFICATION.

OWNER	<input checked="" type="checkbox"/>
ARCHITECT	<input type="checkbox"/>
CONSULTANT	<input type="checkbox"/>
CONTRACTOR	<input type="checkbox"/>
FIELD	<input type="checkbox"/>
OTHER	<input type="checkbox"/>

PROJECT:
SUPPLEMENTAL INSTRUCTION NO: TI- 01
iTAP

ARCHITECT'S
CONTRACT FOR: iTAP

TO:
Brad Lobdell & Sean Conroy
International Tap House

ARCHITECT:
Collins & Webb Architecture
307B SW Market Street
Lee's Summit, Missouri 64063

ARCHITECT'S PROJECT NO.: 22066

The Work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Proceeding with the Work in accordance with these instructions indicates your acknowledgment that there will be no change in the Contract Sum or Contract Time.

Description:

The following changes to permit documents shall be incorporated.

Architectural Narrative:

1. Building is no longer 2hr rated. Disregard 2 Hour Fire Barrier on A3/G003
2. Fire extinguisher cabinet northwest of MEP/iTAP storage to be surface mounted not a recessed fire extinguisher cabinet. Disregard FE-1 FEC tag on A3/G003
3. There is no longer a penetration between iTAP's space and adjacent TI
 - a. Disregard keynote 8 and 25 on A101
 - b. Disregard new opening note on demo plan 1/A101
 - c. Disregard dimensions and glazing types in reference to opening called out on G6/A504
4. Walls around T103 ADA Unisex restroom to go to roof deck. Disregard keynote 17 on A101

Attachments: Structural and MEP's narrative in response to Landlord Revisions, Revised MEP DWGs

ISSUED BY: Addie Forton, Collins & Webb Architecture

(Signature)