

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213148
Address: 508 NW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, May 11, 2023

Corrective Action Required:

2	Misc	-Address pending driveway inspection -Handrail in garage to be 34"-38" from nosing of tread -Handrail grip size in garage to comply with code section -window fall protection for 2nd floor bedroom -Tamper cap at a/c unit
---	------	---

Comments: