

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210734  
Address: 1514 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Failed	Thursday, May 11, 2023

Corrective Action Required:

1	Misc	-Ensure all Arc fault required in breaker panel E3902.16 of the 2018 IRC -Label non GFCI's in basement -need lock out for all hardwired appliances -address post to beam connection at deck - ledger bolts missing at deck -paint gas pipe -obtain an lawn irrigation permit
---	------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: