

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210742
Address: 1518 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, May 11, 2023

Corrective Action Required:

1	Misc	-Ensure all Arc fault required in breaker panel -secure whip to water heater -obtain a lawn irrigation permit - address deck post to beam connection - provide 6" clearance siding to grade
---	------	---

Comments: