

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210734
Address: 1514 SW HEARTWOOD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, May 12, 2023

Corrective Action Required:

1	Misc	-Ensure all Arc fault required in breaker panel E3902.16 of the 2018 IRC missing on disposal and microwave -address post to beam connection at deck -address siding from grade at rear of lot - ledger bolts missing at deck -paint gas pipe -obtain an lawn irrigation permit
---	------	---

Comments: