

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220625
Address: 2018 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ryan Heckman	Passed	Friday, May 12, 2023

Informational:

1 Misc

5-4-23 RH. Driveway is fromed up and aggregate is placed and compacted.
Approved to pour.

5-12-23 RH. Driveway meets LS and ADA specification.

Comments: