

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20230625
Address: 1708 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, May 15, 2023

Corrective Action Required:

1	Misc	-Rafters above front stoop notched more than max allowed of 25% -Deck: install two lag screws at end of ledger board -The rear great room CSPF nailing to header and interior strap
		Okay to insulate

Comments: