

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215283

Address: 3647 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:E, LEES SUMMIT, MO 640643647 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Monday, May 15, 2023

Corrective Action Required:

1 Misc

EXTERIOR:

-Exterior not completed at this time

UNIT A:

-Master bedroom smoke alarm not interconnected

-Install connector at NM entry into furnace

UNIT B:

-Install switch cover plate under kitchen island

-Tighten laundry receptacle

-Install connector at NM entry into furnace

UNIT C:

-Install furnace switch cover plate

-Install connector at NM entry into furnace

UNIT D:

-Replace broken window

-Garage light not working

- Install connector at NM entry into furnace

UNIT E:

- Install kitchen island receptacle cover plate
- Install connector at NM entry into furnace

Comments: