

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231091

Address: 2123 SW OSAGE DR, LEES SUMMIT, MO 640822121 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Kyle Beard	Failed	Monday, May 15, 2023

Corrective Action Required:

1	Miscellaneous Correction	2123 Electrical panel is not Bonded/Grounded
		2121 Passed

Comments: