

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20230813  
Address: 3511 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Kyle Beard	Partial	Tuesday, May 16, 2023

Informational:

1      Misc

4-20-23 RH. Erosion control is up and in working order.

4-24-23 RH. Erosion control is up and in working order.

5-1-23 RH. Erosin Control is up and in working order.

5-12-23 RH. Erosion control is up and in working order for most of site. Due to Storm line being placed some silt fence was knocked down and will need fixed. Contractor is informed and will fix.

5-15-23 RH. Erosion control is up and in working order for most of site. Some silt fence need repaired and contractor is fixing this week.

5-16-23 RH. Erosion control is up and in working order other than the silt that needs repaired.

**Comments:**