

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223170
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	John Jackson	Partial	Tuesday, May 16, 2023

Informational:

1	Misc	04/11/23 Tuesday JMJ (Larry Brown excavating, Inc.) Talked with contractor about installing additional erosion control to contain silt and run-off.
---	------	--

Corrective Action Required:

2	Misc	04/20/23 Thursday JMJ Site erosion control measure have failed on the Westside of project and entrance. Muddy water has run-off on private street Northside of Victoria Street. I will again contact contractor to maintain and control soil erosion of site. 05/16/23 Tuesday JMJ (Bradley Construction) The contractor will need to clean private street of soil erosion that rainfall from the past few days has caused. I will continue to monitor this site for compliance for soil erosion.
---	------	---

Comments: