

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224903
Address: 2607 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, May 16, 2023

Corrective Action Required:

1	Misc	-nail studs at all exterior corner per code -fire blocking missing at ceiling of garage fir down see S garage wall -fireblock mud room to entry furr down -check entire first floor penetrations (house had to be rewired) -install double studs at master vanity at penetrations have engineer address see code figure r602.6(1)
---	------	---

Comments: