CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192646

Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underslab Electrical Inspection Robb Popp Partial Wednesday, May 17,

- Commercial 2023

Corrective Action Required:

1 THE FOLLOWING -Stub ups at west building north side chase location

AREAS ARE APPROVED

Comments: