

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20221459
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Devon Perry	Partial	Wednesday, May 17, 2023

Informational:
1 Misc 5-17-23 DP. Hanrahan Asphalt is currently working on laying surface. They have type 5-01 virgin surface. There were having some inconsistencies with compaction testing. We made them go over it some more to get as close as possible and after talking to steve we are going to see what the 3rd party report says and make a determination from there in areas they might not have 96% compaction.

Comments: