


May 5, 2023

**City of Lee's Summit**  
220 Green Street  
Lee's Summit, MO 64063

**Dear Sue Pyles:**

This memo is in regard to the Old Longview Lake Dam and Spillway Improvement project. While the lake improvements have been completed, the plans reflected a sediment forebay to be installed on the east side behind the existing subdivision. A review has been requested to the benefits of this forebay. During this review it was determined that the benefits this forebay provides to the overall watershed versus the impacts from construction of the forebay was negligible. The construction operations would provide more disturbance in a mature stream area than the benefits as the watershed is majority developed and stabilized at this point. In review of previous permits, the forebay installation was determined not to be a condition of permitting, thus with this letter we request the forebay be removed from the plan set.



Sincerely,



**Julie Sellers, PE**  
Olsson Senior Engineer