

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231815
Address: 2614 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Mitchell Schwarz	Partial	Thursday, May 18, 2023

Corrective Action Required:

1	Misc	-Footing Bonded at 4 points around the perimeter of the pool to tie to the foundation walls
---	------	---

Comments: