CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230813

Address: 3511 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Site Visit Ryan Heckman Partial Friday, May 19, 2023

Informational:

1 Misc 3-30-23 PS Construction pre con meeting took place this morning. Contractor

estimates site work to begin 4-17

4-18-23 RH. Contractor has put in the construciton entrance. Contractor is on

site and is digging some boreholes to check soil conditions.

4-19-23 RH. Contractor is diggin out the building pad today.

4-21-23 RH. No work on site for development in the AM.

4-24-23 RH. Contractor is placing screenings down for building pad. No work for development in the AM. Contractor continued to work on the building

pad in the PM.

4-25-23 RH. Contractor continues to place lime screenings for the building

pad. No work for development in the AM.

4-26-23 RH. Contractor is not doing any work on site in the AM.

4-27-23 RH. Contractor is starting to tie rebar for footings. No work for

development.

4-28-23 RH. Contractor continues to work on footings for the building. No work for development.

5-1-23 RH. Contractor inspected conduit for the electrical going under the future parking lot of enctrance to job site. Conduit was 36" deep and all glued together.

5-2-23 RH. Contractor contiunes to dig trenches for underground electric. No work for development.

5-3-23 RH. Contractor is planning to place geogrid later today.

5-15-23 RH. No work for development in the AM.

5-17-23 RH. Contractor is pouring the building pad today. No work for development in the AM.

5-18-23 RH. Contractor poured the building yesterday. No work on site for development in the AM.

5-19-23 RH. No work on site for development in the AM.

Comments: