

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSGN20230473
Address: 6 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection	Robb Popp	Pending	

Corrective Action Required:

1	Miscellaneous Correction	-Breaker needs a lockout installed. -above ceiling in soffit inspection passed
---	-----------------------------	---

Comments: