

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231176

Address: 2127 SW OSAGE DR, LEES SUMMIT, MO 640822129 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Partial	Friday, May 19, 2023

Informational:

1	Miscellaneous Correction	Silt fence in front and back are installed. Erosion control is required throughout until building final
---	-----------------------------	---

Comments: