

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220642  
Address: 2027 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Monday, May 22, 2023

Corrective Action Required:

1 Misc

NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IS IN COMPLIANCE  
-sod  
-complete downspouts  
-downspouts and sump pump discharge to extend 36" from foundation  
-hardware for rear slider

**Comments:**