

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20230813  
Address: 3511 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Storm Sewer Construction Inspection</b>	Ryan Heckman	Partial	Monday, May 22, 2023

Informational:

1	Misc	5-10-23 RH. Storm Structures were installed for Line 3 Station 0+00 to 0+75. Correct bedding was placed for structures. Rip Rap still needs to be added to the outlet at 0+00.
		5-12-23 RH. Storm Structure 10A for Storm Line 1 was placed over the previously poured line. Structure 32 at station 1+09 was placed and poured around. Collars and inlets were poured for the previously placed storm structures.
		5-22-23 RH. Storm structure 11 is being lowered to match grade for parking lot.

**Comments:**