

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220899

Address: 1024 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811026 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811028 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811030 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811032 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811034 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811036 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811038 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811040 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811042 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811044 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811046 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811022 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, May 22, 2023

Corrective Action Required:

1	Misc	-Complete final grade, sod, foundation drainage -All water meter height will be checked after final grade and sod 1036-GFCI at master bath not working 1042-GFCI at laundry not working, secure receptacles in master bath 1044-Correct top stair elevation at landing 1046-Correct top stair elevation at landing, complete sidewalk
---	------	--

Comments: