

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224097
Address: 2767 SW 12TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Devon Perry	Partial	Monday, May 22, 2023

Informational:
1 Misc 5-22-23 DP. Crew had DW formed, aggregate compacted. Told to keep cross slope in compliance throughout DW approach. Conditions can change.
Approved to pour

Comments: